



SECTION X. Y.  
Scale 1/4" = 1'-0"

Notes: Unless otherwise marked, all gal. iron in attic is to be No. 22.  
Provide pan dampers with roller bearings in each of the three main vent ducts as shown, and run chains to basement.  
Vent piping to run under ducts.

ATTIC FLOOR PLAN  
Scale 1/4" = 1'-0"

HEATING AND VENTILATING PLANS FOR  
SCHOOLHOUSE FOR THE TOWN OF LINCOLN MASS.  
PARKER THOMAS & RICE ARCHITECTS BOSTON & BALTIMORE