



Massachusetts Department of Environmental Protection - Drinking Water Program **PFAS**
Per- and Polyfluoroalkyl Substances (PFAS) Report

Page 1 of 2

I. PWS INFORMATION: Please refer to your DEP Water Quality Sampling Schedule (WQSS) to help complete this form

PWS ID #: **3157000** City / Town: **LINCOLN**
 PWS Name: **Lincoln Water Department** PWS Class: **COM** **NTNC** **TNC**

DEP LOCATION (LOC) ID#	DEP Location Name	Sample Information		Date Collected	Collected By
RW 008	Tower Road Well	<input type="checkbox"/> (M)ultiple <input type="checkbox"/> (S)ingle	<input type="checkbox"/> (R)aw <input type="checkbox"/> (F)inished	3/21/2019	Marybeth Wisner
Routine or Special Sample <input type="checkbox"/> RS <input type="checkbox"/> SS		Original, Resubmitted or Confirmation Report <input checked="" type="checkbox"/> Original <input type="checkbox"/> Resubmitted <input type="checkbox"/> Confirmation		If Resubmitted Report, list below: (1) Reason for Resubmission <input type="checkbox"/> Resample <input type="checkbox"/> Reanalysis <input type="checkbox"/> Report Correction	
(2) Collection Date of Original Sample					
SAMPLE NOTES – Such as, if a Manifold/Multiple sample, list the source(s) that were on-line during sample collection.					

II. ANALYTICAL LABORATORY INFORMATION:

Primary Lab Cert. #: **M-MA1118** Primary Lab Name: **Nashoba Analytical, Llc** Subcontracted? (Y/N) **Y**
 Analysis Lab Cert. #: **M-CT004** Analysis Lab Name: **S. Central Conn. Rwa**
 If Analysis Lab is not certified by MassDEP or U.S. EPA, list certification authority:

Lab Method	Date Extracted	Date Analyzed	Lab Sample ID#	LAB SAMPLE NOTES - Include information as to whether sample was diluted or additional contaminants detected.
EPA 537	3/28/2019	4/6/2019	200065	

CAS#	REGULATED AND UNREGULATED PFAS CONTAMINANTS	Results µg/L	ORSG* µg/L	MRL µg/L
1763-23-1	Perfluorooctane Sulfonic Acid (PFOS)	ND	0.070	0.004
335-67-1	Perfluorooctanoic Acid (PFOA)	ND	0.070	0.002
355-46-4	Perfluorohexane Sulfonic Acid (PFHxS)	ND	0.070	0.003
375-95-1	Perfluorononanoic Acid (PFNA)	ND	0.070	0.002
375-85-9	Perfluoroheptanoic Acid (PFHpA)	ND	0.070	0.002
375-73-5	Perfluorobutane sulfonic acid (PFBS)	ND	-	0.009
335-76-2	Perfluorodecanoic acid (PFDA)	ND	-	0.005
307-55-1	Perfluorododecanoic acid (PFDoA)	ND	-	0.005
307-24-4	Perfluorohexanoic acid (PFHxA)	ND	-	0.005
376-06-7	Perfluorotetradecanoic acid (PFTA)	ND	-	0.005
72629-94-8	Perfluorotridecanoic acid (PFTTrDA)	ND	-	0.005
2058-94-8	Perfluoroundecanoic acid (PFUnA)	ND	-	0.005
2991-50-6	N-ethyl perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	ND	-	0.005
2355-31-9	N-methyl perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	ND	-	0.005
763051-92-9	11-chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)		-	
756426-58-1	9-chlorohexadecafluoro-3-oxanone-1-sulfonic acid (9Cl-PF3ONS)		-	
919005-14-4	4,8-dioxa-3H-perfluorononanoic acid (ADONA)		-	
13252-13-6	Hexafluoropropylene oxide dimer acid (HFPO-DA)		-	

*The MassDEP ORSG is 0.070 µg/L for PFOA, PFOS, PFHxS, PFNA, and PFHpA, individually or added together.



Massachusetts Department of Environmental Protection - Drinking Water Program **PFAS**
Per- and Polyfluoroalkyl Substances (PFAS) Report

Page 1 of 2

I. PWS INFORMATION: Please refer to your DEP Water Quality Sampling Schedule (WQSS) to help complete this form

PWS ID #: **3157000** City / Town: **LINCOLN**
 PWS Name: **Lincoln Water Department** PWS Class: **COM** **NTNC** **TNC**

DEP LOCATION (LOC) ID#	DEP Location Name	Sample Information	Date Collected	Collected By
RW 007	Flint's Pond Raw	<input type="checkbox"/> (M)ultiple <input type="checkbox"/> (S)ingle <input type="checkbox"/> (R)aw <input type="checkbox"/> (F)inished	3/21/2019	Marybeth Wisner

Routine or Special Sample	Original, Resubmitted or Confirmation Report	If Resubmitted Report, list below:	
		(1) Reason for Resubmission	(2) Collection Date of Original Sample
<input type="checkbox"/> RS <input type="checkbox"/> SS <input checked="" type="checkbox"/> Original <input type="checkbox"/> Resubmitted <input type="checkbox"/> Confirmation	<input type="checkbox"/> Resample <input type="checkbox"/> Reanalysis <input type="checkbox"/> Report Correction		

SAMPLE NOTES – Such as, if a Manifold/Multiple sample, list the source(s) that were on-line during sample collection.

II. ANALYTICAL LABORATORY INFORMATION:

Primary Lab Cert. #: **M-MA1118** Primary Lab Name: **Nashoba Analytical, Llc** Subcontracted? (Y/N) **Y**

Analysis Lab Cert. #: **M-CT004** Analysis Lab Name: **S. Central Conn. Rwa**

If Analysis Lab is not certified by MassDEP or U.S. EPA, list certification authority:

Lab Method	Date Extracted	Date Analyzed	Lab Sample ID#	LAB SAMPLE NOTES - Include information as to whether sample was diluted or additional contaminants detected.
EPA 537	3/28/2019	4/6/2019	200064	

CAS#	REGULATED AND UNREGULATED PFAS CONTAMINANTS	Results µg/L	ORSG* µg/L	MRL µg/L
1763-23-1	Perfluorooctane Sulfonic Acid (PFOS)	ND	0.070	0.004
335-67-1	Perfluorooctanoic Acid (PFOA)	ND	0.070	0.002
355-46-4	Perfluorohexane Sulfonic Acid (PFHxS)	ND	0.070	0.003
375-95-1	Perfluorononanoic Acid (PFNA)	ND	0.070	0.002
375-85-9	Perfluorohepatanoic Acid (PFHpA)	ND	0.070	0.002
375-73-5	Perfluorobutane sulfonic acid (PFBS)	ND	-	0.009
335-76-2	Perfluorodecanoic acid (PFDA)	ND	-	0.005
307-55-1	Perfluorododecanoic acid (PFDoA)	ND	-	0.005
307-24-4	Perfluorohexanoic acid (PFHxA)	ND	-	0.005
376-06-7	Perfluorotetradecanoic acid (PFTA)	ND	-	0.005
72629-94-8	Perfluorotridecanoic acid (PFTrDA)	ND	-	0.005
2058-94-8	Perfluoroundecanoic acid (PFUnA)	ND	-	0.005
2991-50-6	N-ethyl perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	ND	-	0.005
2355-31-9	N-methyl perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	ND	-	0.005
763051-92-9	11-chloroicoisafuoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)		-	
756426-58-1	9-chlorohexadecafluoro-3-oxanone-1-sulfonic acid (9Cl-PF3ONS)		-	
919005-14-4	4,8-dioxa-3H-perfluorononanoic acid (ADONA)		-	
13252-13-6	Hexafluoropropylene oxide dimer acid (HFPO-DA)		-	

*The MassDEP ORSG is 0.070 µg/L for PFOA, PFOS, PFHxS, PFNA, and PFHpA, individually or added together.

